



DECLARATION OF CONFORMITY

Tri plus grupa d.o.o. declares that this product is in compliance with the essential requirements and other relevant provisions of Directives as follows:

Model: ZIPABOX-BACKUP-V5
Intended use: indoor

EMC Directive (2004/108/EC)
Low Voltage Directive (2006/95/EC)
R&TTE Directive (1999/5/EC)

The product is compatible with following norms/standards:

EN 60950-1:2007+A11:2009+A12:2011
EN 301 489-17 V2.1.1:2010
EN 301 489-3 V1.4.1:2003
EN 301 489-1 V1.8.1:2008
EN 300 328 V1.7.1:2008
EN 50130-4:1977+A1:2000+A2:2004
EN 300 220-1 V2.1.1:2006
EN 300 220-2 V2.1.2:2008

Manufacturer/Authorised representative,

TRI PLUS GRUPA
d.o.o.
ZAGREB

Dean Janacek

Zagreb, 12 September 2012

Tri plus grupa d.o.o.
Banjaveciceva 11
10000 Zagreb
Croatia

Backup expansion module



COMPATIBILITY

This expansion module is designed to work only with Zipabox with software version 0.9.962 or later.

HANDLING

Do not drop, knock or shake the module. Rough handling can break internal circuit boards and connectors.

ENVIRONMENT

Do not expose the module to excessive heat or cold, as it can damage or shorten the life of electronic circuit boards and battery. If possible, dispose this module at a recycling center. Do not dispose of this module with the household waste.

SPECIFICATION


Power supply:	from Zipabox
Operating temperature:	-10° ~ +40° C
Operating humidity:	5 ~ 95% RH
Dimensions:	55 x 87 x 46 mm
Weight:	205g
Battery:	3500 mAh, 7.4 V
Port:	USB, RS232

UNPACKING

Backup expansion module consists of:


- 1x expansion module
- 1x GSM stick (optional)

- Connect GSM stick to USB port of the Backup module (optional).
- Optional RS232 connection:




CONNECTING DEVICE

1. Disconnect Zipabox from power;
2. If you had any other module in Slot 1 remove it;
3. Align connector of Backup expansion module to expansion Slot 1 of Zipabox;



4. Join module and Zipabox together until gap between them is completely closed;



5. If you had any other module in Slot 1 connect it back to Backup module in a same way.

INSTALLATION/MOUNTING

Mount together with Zipabox.

TESTING

1. Battery in Backup module comes charged
2. When Backup module is first time connected to Zipabox upper LED is red indicating battery is discharging
3. When ZipaBox is connected back to power supply upper LED will become green
4. When battery is charging lower LED is blue
5. The lower LED slow blinking in blue indicates battery error.

REPAIRING

Do not attempt to repair this product. There are no user-serviceable parts inside.

WATER-RESISTANCE

This product is not water-resistant. Keep it dry. Moisture will corrode the inner electronics.

CLEANING

Use a dry cloth to clean this product. Do not use harsh chemicals, cleaning solvents or strong detergents.

COPYRIGHT

The contents of this manual is subject to copyright protection. Copying and reproducing is prohibited without prior written permission. Information in this document is subject to change without prior notice. Check www.zipato.com for updates.



DECLARATION OF CONFORMITY

Tri plus grupa d.o.o. declares that this product is in compliance with the essential requirements and other relevant provisions of Directives as follows:

Model: ZIPABOX-ZIGBEE-V1
Intended use: indoor

EMC Directive (2004/108/EC)
Low Voltage Directive (2006/95/EC)
R&TTE Directive (1999/5/EC)

The product is compatible with following norms/standards:

EN 60950-1:2007+A11:2009+A12:2011
EN 301 489-17 V2.1.1:2010
EN 301 489-3 V1.4.1:2003
EN 301 489-1 V1.8.1:2008
EN 300 328 V1.7.1:2008
EN 50130-4:1977+A1:2000+A2:2004
EN 300 220-1 V2.1.1:2006
EN 300 220-2 V2.1.2:2008

Manufacturer/Authorised representative,



TRI PLUS GRUPA
d.o.o.
ZAGREB

Dean Janacek

Zagreb, 12 September 2012

Tri plus grupa d.o.o.
Banjaveciceva 11
10000 Zagreb
Croatia